



NOTES :

1. ALL WELDING TO BE 4mm THICK FOR ALL MEMBERS CONNECTION AND TO BE PROVIDED ALL ROUND.
2. ALL PLATES ARE TO BE 50mm X 6mm STAINLESS STEEL PLATES.
3. UNLESS OTHERWISE SPECIFIED, ALL ANGLE ARE TO BE 50mm X 50mm X 5mm STAINLESS STEEL ANGLE BRACKET.
4. BOLTING CONNECTION TO USE GALVANISED EXPANSION BOLTS AND NUTS. THE SIZE OF BOLT USED IS 12mmØ FOR RC WALL.
5. 13mmØ GALVANISED DRILLED THROUGH BOLTS WITH 50mm X 6mm THICK STAINLESS STEEL PLATE FOR BRICKWALL.
6. MAX. WT. 110kg.
7. ANCHORING SYSTEM SUCH AS MECHANICAL ANCHORS, EXPANSION BOLTS ... ETC USED MUST BE AT LEAST MEDIUM DUTY AND ABOVE.

DRAWING A3

DRAWING TITLE

DETAIL OF ANGLE SUPPORT FOR AIR CONDENSING UNIT AT AIR-CON OPENING IN THE MASTER BEDROOM (DRAWING A3)

COPYRIGHT RESERVED

1. Measurements shown in or taken from this drawing are to be verified on site.
2. No part of this drawing shall be duplicated or distributed without written consent from HDB.
3. This drawing is served as a guide only.

PLAN NO: SED 007C

PLAN NAME: STD ACU MA3

DATE: AUG 2004