



- NOTE:
- 1) THE AIR-CON CONDENSING UNIT (ACU) MUST BE PLACED ON THE LEDGE WITHIN THE RAILING.
  - 2) FLAT OWNERS ARE ALLOWED TO PLACE TWO ACUs SIDE BY SIDE ON THE LEDGE.
  - 3) THE ACU SHOULD NOT BE IN CONTACT WITH THE RAILING AND WALLS AFTER INSTALLATION.
  - 4) RUBBER PAD SHOULD BE PROVIDED AT THE BASE OF THE ACU TO CUSHION ANY VIBRATION.

**DRAWING K**

DRAWING TITLE :

**AIR - CONDITIONER LEDGE  
{DRAWING K}**

Note: This drawing is served as a guide only.

DATE: OCTOBER 2008